

Enerlin'X

FDM121 Front Display Module for One Circuit Breaker

Firmware Release Notes

DOCA0150EN-07
03/2023



Legal Information

The Schneider Electric brand and any trademarks of Schneider Electric SE and its subsidiaries referred to in this guide are the property of Schneider Electric SE or its subsidiaries. All other brands may be trademarks of their respective owners.

This guide and its content are protected under applicable copyright laws and furnished for informational use only. No part of this guide may be reproduced or transmitted in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), for any purpose, without the prior written permission of Schneider Electric.

Schneider Electric does not grant any right or license for commercial use of the guide or its content, except for a non-exclusive and personal license to consult it on an "as is" basis. Schneider Electric products and equipment should be installed, operated, serviced, and maintained only by qualified personnel.

As standards, specifications, and designs change from time to time, information contained in this guide may be subject to change without notice.

To the extent permitted by applicable law, no responsibility or liability is assumed by Schneider Electric and its subsidiaries for any errors or omissions in the informational content of this material or consequences arising out of or resulting from the use of the information contained herein.

As part of a group of responsible, inclusive companies, we are updating our communications that contain non-inclusive terminology. Until we complete this process, however, our content may still contain standardized industry terms that may be deemed inappropriate by our customers.

Table of Contents

Introduction	5
FDM121 Front Display Module for One Circuit Breaker	5
Firmware Release History	5
Firmware Update Policy	6
Firmware Update with EcoStruxure Power Commission Software	6
Firmware Versions	7
Firmware Version 004.000.013	7
Firmware Version 004.000.011	7
Firmware Version 004.000.009	7
Firmware Version 003.000.028	7
Firmware Version 003.000.025	8
Firmware Version 003.000.023	8
Firmware Version 003.000.022	8
Firmware Version 003.000.016	8
Firmware Version 003.000.013	9
Related Documents	10

Introduction

FDM121 Front Display Module for One Circuit Breaker

The FDM121 display shows the measurements, alarms, and operating assistance data from the intelligent modular unit (IMU). The FDM121 display can control a circuit breaker that is equipped with a motor mechanism or with the pre-defined application performed by the IO module.

The FDM121 display with part number TRV00121 or STRV00121 is compatible with the following ranges of circuit breaker:

- MasterPact MTZ circuit breakers
- MasterPact NT/NW circuit breakers
- ComPacT NS circuit breakers
- ComPacT NSX circuit breakers
- PowerPacT P- and R-frame circuit breakers
- PowerPacT H-, J-, and L-Frame circuit breakers

NOTE:

- The information related to the new generation of ComPacT NS and PowerPacT P- and R-frame circuit breakers in this document applies to the existing range ComPacT NS and PowerPacT P- and R-frame circuit breakers also. The exceptions are mentioned wherever applicable.
- The information related to the new generation of ComPacT NSX and PowerPacT H-, J-, and L-Frame circuit breakers in this document applies to the existing range ComPacT NSX and PowerPacT H-, J-, and L-frame circuit breakers also. The exceptions are mentioned wherever applicable.
- These new ranges are based on the same technical and dimensional architecture as that of the existing range of circuit breakers.

Firmware Release History

Date	Firmware version	Availability
February 2023	004.000.013	Release for manufacturing
February 2022	004.000.011	Obsolete
October 2021	004.000.009	Obsolete
July 2021	003.000.028	Obsolete
December 2020	003.000.025	Obsolete
August 2019	003.000.023	Obsolete
March 2019	003.000.022	Obsolete
June 2018	003.000.016	Obsolete
January 2018	003.000.013	Obsolete

NOTE: FDM121 firmware versions 003.000.013 or greater are compatible with FDM121 hardware with date code WX18141 or greater. Hardware with date code lower than WX18141 cannot be updated with firmware versions 003.000.013 or greater.

Firmware Update Policy

Firmware update is recommended to benefit from the latest features and potential bug fixes. Do not update the firmware to the latest version, if the latest features are not required for your application and no bug fixes are provided.

Use this release note to confirm if an update to the latest version of the FDM121 firmware is relevant to your application.

For more information on the firmware update policy and the firmware compatibility between devices, refer to [DOCA0155EN MicroLogic Trip and Control Units - Firmware History](#).

Firmware Update with EcoStruxure Power Commission Software

Use the latest version of EcoStruxure Power Commission software to:

- Check the firmware compatibility of the devices in the IMU.
- Update the devices with the latest firmware version available.

After updating the firmware of one device, use EcoStruxure Power Commission software to check the firmware compatibility between IMU devices.

The Firmware Update table helps the user to diagnose and identify all discrepancy issues between IMU devices. This table also provides the recommended actions for each discrepancy issue.

The latest version of EcoStruxure Power Commission software is available at www.se.com.

For more information about the use of EcoStruxure Power Commission software, refer to *EcoStruxure Power Commission Online Help*.

Firmware Versions

Firmware Version 004.000.013

Security Updates

Enabled password protection for firmware update of FDM121 display via EcoStruxure Power Commission software.

New Features

Manual factory reset of FDM121 display to its default factory settings.

Firmware Version 004.000.011

New Features

Added **Alarm History** and **New event** pop-up features for MasterPact MTZ circuit breaker.

NOTE: For compatibility issue with older firmware versions (003.000.028 and earlier), refer to section Troubleshooting: Control Operations from FDM121 Display in the *DOCA0101EN – MasterPact MTZ2/MTZ3 IEC Circuit Breakers and Switch-Disconnectors from 800 to 6300 A – User Guide*.

Firmware Version 004.000.009

New Features

Supports MasterPact MTZ circuit breaker and provides the following features:

- Metering
- Breaker status and control
- Device identification
- Reset (peak demand values, energy meters, minimum and maximum values)
- Maintenance (operation counters, load profile)

NOTE: **Alarm History** and **New event** pop-up features are not available for MasterPact MTZ circuit breaker.

Firmware Version 003.000.028

New Features

- Added **Product ID** screen for MasterPact NT/NW, ComPacT NS, and PowerPacT P- and R-frame circuit breakers.

Bugs Fixed

- The part number of MicroLogic trip unit displayed on the **Product ID** screen was flickering when connected to ComPacT NSX and PowerPacT H-, J-, and L-Frame circuit breakers.

Firmware Version 003.000.025

Bugs Fixed

- ComPacT NSX breaker operation was not always possible after power restoration.
- On the ground fault event, the current value **I_g** was not displayed as **NA** in **Alarm History** screen.

Firmware Version 003.000.023

NOTE: Release for manufacturing of firmware version 003.000.022.

Firmware Version 003.000.022

NOTE: The firmware version 003.000.022 is released through EcoStruxure Power Commission (EPC) software.

New Features

- Minor improvements in bar and dial graph screens.

Bugs Fixed

- Values were randomly not displayed in **Quick View** and **Metering** screens on change of Breaker System type or Breaker.
- **Product ID** screen showed inconsistent pictures for ULP devices.
- **IO Lighting** and **Load control** ON/OFF status was inconsistent with actual status.
- Event pop-up was inconsistently displayed when user was in **Quick View** screen on power on.
- **Close Self Timer** screen did not stop timer countdown on occurrence of an event.

Firmware Version 003.000.016

Bugs Fixed

- Size of Chinese characters displayed on the screen was not consistent.

Firmware Version 003.000.013

New Features

- All 14 languages supported by default.
- Improvement of the performance of the metering screen for reading values and navigation.
- Added QR code display to access information about the FDM121 display.
- Added new signature revocation mechanism to enhance cybersecurity.

Related Documents

The following table lists the documents that are compatible with a FDM121 display with the latest firmware version:

Title of documentation	Publication date	Reference number
<i>Enerlin'X FDM121 – Front Display Module for One Circuit Breaker – User Guide</i>	10/2021	DOCA0088EN
<i>ULP System (IEC Standard) – ULP (Universal Logic Plug) System – User Guide</i>	03/2019	DOCA0093EN
<i>ULP System (UL Standard) – ULP (Universal Logic Plug) System – User Guide</i>	03/2019	0602IB1503

You can download these technical publications and other technical information from our website at www.se.com/ww/en/download.

If the document with the revision index is not available on our website, contact your Customer Care Centre to obtain it from the documentation repository.

Schneider Electric
35 rue Joseph Monier
92500 Rueil Malmaison
France

+ 33 (0) 1 41 29 70 00

www.se.com

As standards, specifications, and design change from time to time,
please ask for confirmation of the information given in this publication.

© 2023 Schneider Electric. All rights reserved.

DOCA0150EN-08