

TeSys Active

TeSys Tera Motor Management System

Firmware Release Notes

DOCA0276EN-02
03/2026



Legal Information

The information provided in this document contains general descriptions, technical characteristics and/or recommendations related to products/solutions.

This document is not intended as a substitute for a detailed study or operational and site-specific development or schematic plan. It is not to be used for determining suitability or reliability of the products/solutions for specific user applications. It is the duty of any such user to perform or have any professional expert of its choice (integrator, specifier or the like) perform the appropriate and comprehensive risk analysis, evaluation and testing of the products/solutions with respect to the relevant specific application or use thereof.

The Schneider Electric brand and any trademarks of Schneider Electric SE and its subsidiaries referred to in this document are the property of Schneider Electric SE or its subsidiaries. All other brands may be trademarks of their respective owner.

This document and its content are protected under applicable copyright laws and provided for informative use only. No part of this document may be reproduced or transmitted in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), for any purpose, without the prior written permission of Schneider Electric.

Schneider Electric does not grant any right or license for commercial use of the document or its content, except for a non-exclusive and personal license to consult it on an "as is" basis.

Schneider Electric reserves the right to make changes or updates with respect to or in the content of this document or the format thereof, at any time without notice.

To the extent permitted by applicable law, no responsibility or liability is assumed by Schneider Electric and its subsidiaries for any errors or omissions in the informational content of this document, as well as any non-intended use or misuse of the content thereof.

Table of Contents

- Safety Information.....5
- About the Book.....6
- Introduction9
 - Release History.....9
- Firmware Versions 10
 - LTMT Ethernet Main Module Version 001.000.003 and Version 001.000.004..... 10
 - LTMT Modbus RTU and PROFIBUS DP Version 002.001.002 10
- Compatibility 11
- TeSys Tera Firmware..... 12
 - Firmware Update Policy 12
 - Configuration Software 12
 - TeSys Tera Firmware Update..... 12
 - LTMTCUF Control Operator Unit Firmware Update 12

Safety Information

Important Information

Read these instructions carefully, and look at the equipment to become familiar with the device before trying to install, operate, service, or maintain it. The following special messages may appear throughout this documentation or on the equipment to warn of potential hazards or to call attention to information that clarifies or simplifies a procedure.



The addition of this symbol to a “Danger” or “Warning” safety label indicates that an electrical hazard exists which will result in personal injury if the instructions are not followed.



This is the safety alert symbol. It is used to alert you to potential personal injury hazards. Obey all safety messages that follow this symbol to avoid possible injury or death.

⚠ DANGER

DANGER indicates a hazardous situation which, if not avoided, **will result in** death or serious injury.

⚠ WARNING

WARNING indicates a hazardous situation which, if not avoided, **could result in** death or serious injury.

⚠ CAUTION

CAUTION indicates a hazardous situation which, if not avoided, **could result in** minor or moderate injury.

NOTICE

NOTICE is used to address practices not related to physical injury.

Please Note

Electrical equipment should be installed, operated, serviced, and maintained only by qualified personnel. No responsibility is assumed by Schneider Electric for any consequences arising out of the use of this material.

A qualified person is one who has skills and knowledge related to the construction and operation of electrical equipment and its installation, and has received safety training to recognize and avoid the hazards involved.

About the Book

Document Scope

This document provides the version history of firmware packages for the TeSys Tera system.

Validity Note

This document is valid only for the firmware packages with the TeSys Tera system.

General Cybersecurity Information

In recent years, the growing number of networked machines and production plants has seen a corresponding increase in the potential for cyber threats, such as unauthorized access, data breaches, and operational disruptions. You must, therefore, consider all possible cybersecurity measures to help protect assets and systems against such threats.

To help keep your Schneider Electric products secure and protected, it is in your best interest to implement the cybersecurity best practices as described in the [Cybersecurity Best Practices](#) document.

Schneider Electric provides additional information and assistance:

- [Subscribe to the Schneider Electric security newsletter.](#)
- [Visit the Cybersecurity Support Portal web page to:](#)
 - [Find Security Notifications.](#)
 - [Report vulnerabilities and incidents.](#)
- [Visit the Schneider Electric Cybersecurity and Data Protection Posture web page to:](#)
 - [Access the cybersecurity posture.](#)
 - [Learn more about cybersecurity in the cybersecurity academy.](#)
 - [Explore the cybersecurity services from Schneider Electric.](#)

Product Related Cybersecurity Information

Refer to *TeSys Tera Motor Management System Cybersecurity Guide – DOCA0260EN*.

Environmental Data

For product compliance and environmental information, refer to the Schneider Electric Environmental Data Program.

Available Languages of the Document

The document is available in these languages:

- English
- Chinese
- French
- German
- Italian
- Korean
- Spanish

Online Information

The information contained in this document is likely to be updated at any time. Schneider Electric strongly recommends that you have the most recent and up-to-date version available on www.se.com/ww/en/download/.

The technical characteristics of the devices described in the present document also appear online. To access the information online, go to the Schneider Electric home page.

Related Documents

Title of documentation	Description	Reference number
TeSys Tera Motor Management System User Guide	This is the main user guide that introduces the complete TeSys Tera system. It describes the main functions of the LTMT main units, LTMTCT/LTMTCTV sensor modules, LTMT expansion modules, and LTMTCUF control operator unit.	DOCA0257EN
TeSys Tera Motor Management System Installation Guide	This guide describes the installation, commissioning, and maintenance of the LTMT main units, LTMTCT/LTMTCTV sensor modules, LTMT expansion modules, and LTMTCUF control operator unit.	DOCA0356EN
TeSys Tera Motor Management System Modbus RTU Communication Guide	This guide describes the Modbus network protocol communication of the LTMT main unit.	DOCA0355EN
TeSys Tera Motor Management System PROFIBUS DP Guide	This guide describes the PROFIBUS DP network protocol communication of the LTMT main unit.	DOCA0256EN
TeSys Tera Motor Management System LTMTCUF control operator unit User Guide	This guide describes how to install, configure, and use the LTMTCUF control operator unit.	DOCA0233EN
TeSys Tera Motor Management System DTM library Online Help Guide	This guide describes the TeSys Tera DTM library which allows the customization of the control functions of the TeSys Tera Motor Management System.	DOCA0275EN
TeSys Tera Motor Management System DTM library Release Note	This document provides important information about the TeSys Tera DTM Library software and provides summary of new features and enhancement.	DOCA0279EN
TeSys Tera Motor Management System EtherNet/IP Guide	This guide describes the EtherNet/IP network protocol communication of the LTMT main unit.	DOCA0258EN
TeSys Tera Motor Management System Cybersecurity Guide	This guide provides information on cybersecurity aspects for the TeSys Tera Motor Management System. This guide addresses on how to secure your operational technology network, or your company serial or Ethernet network.	DOCA0260EN

You can download these technical publications and other technical information from our website at www.se.com.

Information on Non-Inclusive or Insensitive Terminology

As a responsible, inclusive company, Schneider Electric is constantly updating its communications and products that contain non-inclusive or insensitive terminology. However, despite these efforts, our content may still contain terms that are deemed inappropriate by some customers.

Trademarks

QR Code is a registered trademark of DENSO WAVE INCORPORATED in Japan and other countries.

Introduction

Overview

The TeSys Tera system helps to provide complete protection, control, and monitoring capabilities for single-phase or three-phase AC induction motors. The system is installed in the low voltage switchgear system and connects the higher level automation system through fieldbus network and the motor feeder.

These firmware packages support the following LTMT main units of the TeSys Tera system:

- LTMTEBD
- LTMTEFM
- LTMTMBD
- LTMTMFM
- LTMTPFM
- LTMTPBD

NOTE: Firmware for the LTMTCT/LTMTCTV sensor module and the LTMT expansion modules are updated by the respective LTMT main units.

For more information, refer to *TeSys Tera Motor Management System User Guide – DOCA0257EN*

Release History

The following table provides the version history of the TeSys Tera system firmware packages, with the firmware version included into the package for:

Firmware version	Date	Components
TeSysTera_Ethernet_V001.000.004.sedp (LTMTE••)	March 2026	<ul style="list-style-type: none"> • LTMT main units V001.000.004 • LTMTCT/LTMTCTV sensor modules V002.000.000 • LTMT expansion modules V002.004.000
TeSysTera_Ethernet_V001.000.003.sedp (LTMTE••)	March 2026	<ul style="list-style-type: none"> • LTMT main units V001.000.003 • LTMTCT/LTMTCTV sensor modules V002.000.000 • LTMT expansion modules V002.004.000
TeSysTera_Serial_V002.001.002.sedp (LTMTM•• and LTMTPF••)	March 2026	<ul style="list-style-type: none"> • LTMT main units V002.001.002 • LTMTCT/LTMTCTV sensor modules V002.000.000 • LTMT expansion modules V002.004.000
TeSysTera_Ethernet_V001.000.000.sedp (LTMTE••)	November 2025	<ul style="list-style-type: none"> • LTMT main units V001.000.000 • LTMTCT/LTMTCTV sensor modules V002.000.000 • LTMT expansion modules V002.000.000
TeSysTera_Serial_V002.000.000.sedp (LTMTM•• and LTMTPF••)	February 2025	<ul style="list-style-type: none"> • LTMT main units V002.000.000 • LTMTCT/LTMTCTV sensor modules V002.000.000 • LTMT expansion modules V002.000.000

Firmware Versions

LTMT Ethernet Main Module Version 001.000.003 and Version 001.000.004

New Features

Security Feature Enhancement.

LTMT Modbus RTU and PROFIBUS DP Version 002.001.002

New Features

Analog module and overload starter is implemented.

Compatibility

The following table shows the compatibility of configuration or programming softwares with the TeSys Tera system in active releases.

TeSys Tera firmware package version	DTM version	LTMTCUF control operator unit firmware version	LTMTCUF Programmer tool version
TeSysTera_Ethernet_V001.000.004.sedp (LTMTÉ••)	DTM v2.0.1	TeSys Tera_HMI_V002.000.027_sedp	Integrated to DTM
TeSysTera_Ethernet_V001.000.003.sedp (LTMTÉ••)	DTM v2.0.1	TeSys Tera_HMI_V002.000.027_sedp	Integrated to DTM
TeSysTera_Ethernet_V001.000.000.sedp (LTMTÉ••)	DTM v2.0.1	TeSys Tera_HMI_V002.000.026_sedp	Integrated to DTM
TeSysTera_Serial_V002.001.002.sedp (LTMTM•• and LTMTMTP••)	DTM v2.0.1	TeSys Tera_HMI_V002.000.027_sedp	Integrated to DTM
TeSysTera_Serial_V002.000.000.sedp (LTMTM•• and LTMTMTP••)	DTM v2.0.1	TeSys Tera_HMI_V002.000.027_sedp	Integrated to DTM

NOTE: For TeSys Tera Ethernet, if firmware version is less than TeSys Tera_Ethernet_V001.000.003.sedp, then it requires a mandatory update to version TeSys Tera_Ethernet_V001.000.003.sedp

TeSys Tera Firmware

Firmware Update Policy

Firmware update is recommended to benefit from the latest features and potential bug fixes. It is recommended not to update the firmware to the latest version, if the latest features are not required for your application.

Use this release note to determine whether an update to the latest version of the TeSys Tera firmware is relevant for your application.

Configuration Software

Use SoMove v2.9.9 or later with TeSys Tera DTM library v2.0.1 to update the firmware of the TeSys Tera system.

TeSys Tera Firmware Update

The firmware of the LTMT main unit and the modules connected to it are updated in the same operation.

Use TeSys Tera DTM Library to update the firmware of the TeSys Tera system.

For more information on updating the firmware, refer to *TeSys Tera Motor Management System DTM Library Online Help Guide – DOCA0275EN*

LTMTCUF Control Operator Unit Firmware Update

For more information on LTMTCUF firmware upgrade and language files upgrade using DTM, refer to *TeSys Tera Motor Management System DTM Library Online Help Guide – DOCA0275EN*

Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil Malmaison
France

www.se.com

As standards, specifications, and design change from time to time, please ask for confirmation of the information given in this publication.

© 2026 Schneider Electric. All rights reserved.

DOCA0276EN-02